



5330 East 25th Street
Indianapolis Indiana 46218
Phone: (888) 445-4142
www.tepid.com

Installation &
Maintenance Manual
Certified to ANSI Z358.1



Stingray Systems SERIES S5000 Floor Mounted Emergency Combination Shower & Eye/Face Wash

In order to comply with the ANSI Z358.1 Standard the following notes should be observed:

- Station should be assembled and installed in accordance with the manufacturer's instructions, including flushing fluid delivery requirements.
- Station should be in accessible locations that require no more than 10 seconds to reach. The combination station shall be located on the same level as the hazard and the path of travel shall be free of obstructions that may inhibit its immediate use.
- Station should be located in an area identified with a highly visible sign positioned so the sign shall be visible within the area served by the combination station. The area around the combination station shall be well lit.
- Eye/Face wash shall be positioned with nozzles not less than 33 inches (83.8 cm) and no greater than 45 inches (114.3 cm) from surface on which user stands and 6 inches (15.3 cm) minimum from wall or nearest obstructions.
- Shower shall be positioned so that the shower head is not less than 82 inches (208.3 cm) nor more than 96 inches (243.8 cm) from surface on which user stands.
- Shower spray pattern shall have a minimum unobstructed diameter of 20 inches (50.8 cm) at 60 inches (152.4 cm) above surface on which user stands, and center of spray pattern shall be located at least 16 inches (40.6 cm) from any obstruction.
- Eye/Face wash flow pattern shall be not less than 33 inches (83.8cm) and no greater than 53 inches (134.6 cm) from surface on which user stands and 6 inches (15.3 cm) minimum from wall or nearest obstruction.
- If shut off valves are installed in the supply line for maintenance purposes, provisions shall be made to prevent unauthorized shut off.
- Refer to ANSI Z358.1 to ensure compliance.



NOTES: It is recommended to flush pipes prior to installing emergency fixture. Instructions should be reviewed prior to starting the installation. Remove parts from packaging and verify all necessary parts are accounted for and not damaged. Please contact Stingray Systems for any missing or damaged parts prior to starting installation.

Stingray Systems recommends that you work safely at all times and in a manner consistent with the OSHA Lock/Tagout standard, 29 CFR 1910.147 and other applicable standards.

INSTALLATION SUPPLIES

Supplies Included:


- Floor Mount Plate ✓
- Base Piping ✓
- Upper Manifold Assembly ✓
- Bowl Assembly ✓
- Eye/Face Wash Block ✓
- Lower Manifold Assembly ✓
- Dust Covers ✓
- Upper Piping ✓
- Drench Pull Handle ✓
- Shower Arm Assembly ✓
- Shower Head ✓

Supplies Required (Not Included):

- Pipe Sealant or Teflon Tape - To Be Used On All Piping Connections
- (3) 3/8" Floor Anchors Specific for Floor Substrate

PEDESTAL INSTALLATION

1. Remove loose tee with loose plug (temporarily threaded to the **Upper Piping**), and set aside. Thread plug into permanent tee. Thread **Upper Piping** into permanent tee. Thread **Lower Manifold Assembly** onto end of Floor Base Assembly. Insuring that drain connection is located to the rear of the unit or away from where user where stand, thread next section of pipe to **Lower Manifold Assembly**.
2. Remove loose "T" with plug, set aside. Install plug into hard mounted "T". Thread **Upper Piping** into "T".
3. Install "T" into **Upper Piping**.
4. Thread **Shower Arm Assembly** into "T" as shown.
5. Position partially assembled unit at final location. Using the **Floor Mount Plate** as a template, install three anchors (not included) into the floor. Secure partially assembled unit to the floor with the anchors.
6. Insert **Bowl Assembly** into **Lower Manifold Assembly** with red drainpipe going into drain fitting. Press fit drain fitting on **Lower Manifold Assembly** to red drainpipe on **Bowl Assembly**. Tighten setscrews on side of Manifold to support tube.
7. Loop **Dust Covers** onto inlet tube on **Eye/Face Wash Block**. Secure the **Eye/Face Wash Block** to the **Bowl Assembly** by ensuring the legs of the block straddle the tab on the bowl.
8. Attach **Drench Pull Handle** by placing Nylon Washer on each side of outer hole on shower activator arm. Insert **Drench Pull Handle** through hole. Lock into place by inserting Cotter Pins into holes of **Drench Pull Handle**. Thread **Shower Head** to station. Note: For barrier free installations, thread the two-piece pull handle together.
9. Mount sign near (or onto) the assembled unit at the desired location.
10. Ensure the activator is pushed upward in the "off" position. Then, connect 1" NPT supply piping to assembled station. Installer to provide sufficient support of piping; assembled station should *not* be relied on as piping support.





11. Connect 1" NPT drain piping to drain outlet at the bottom of the station.
12. Open supply line to check for leaks. Push on activator to insure adequate flow and drainage through **Eye/Face Wash Block**. Pull back to stop water flow. Pull down on **Drench Pull Handle** to insure adequate flow through showerhead. Push up on **Drench Pull Handle** to stop water flow from shower.

FIXTURE TROUBLESHOOTING

Problem	Checklist
No flow.	Make sure the water supply for station is on. Verify checks of Manifold Assembly correctly installed.
Water does not drain properly.	Check to see if station is installed level and correct as needed. Make sure nothing is blocking drain of the bowl. Remove any debris. Make sure Blocking Coupler is installed property at bottom of "T" as shown in instructions. Double check the main waste line for the facility. Make sure there is no blockage and that it can handle the required drainage.
Water leaks between fittings or connections.	Tighten all connections. If leak persists, disassemble, apply additional sealant and reassemble.
Insufficient flow to eye/face wash.	Turn water supply to station off. Remove the eye pieces and clean out any debris. Make sure diverter is fully opened. Verify pressure to station is at 30 psi as required.
Insufficient flow from shower head.	Turn water supply to station off. Remove shower head and clean out any debris. Make sure actuator is fully opened (pull handle completely engaged). Verify pressure to station is at 30 psi as required.

VALVE TROUBLESHOOTING

Problem	Checklist
No hot water.	Ensure hot water is on. Check pressure at both inlets. Pressures must be near-equal, or seats will check and only allow cold water. Need at least 30 psi at both hot and cold inlets. Need at least a 20 degree difference between hot water and set temperatures, as well as cold water and set temperatures. Inspect checks for debris; clean/replace if needed. Remove thermostat and check for debris. Make sure liner can move. Clean thermostat. If continues, replace thermostat.
No cold water.	Ensure hot connects to hot side; cold to cold side. Inspect checks for debris; clean/replace if needed. Remove thermostat and check for debris. Ensure liner can move. Clean thermostat. Replace thermostat if needed.
No water.	Ensure hot water is on. Check pressure at both inlets. Pressures must be near-equal, or seats will check and only allow cold water. Need at least 30 psi at both hot and cold inlets. Need at least a 20 degree difference between hot water and set temperatures, as well as cold water and set temperatures. Inspect checks for debris; clean/replace if needed. Remove thermostat and check for debris. Ensure liner can move. Clean thermostat. Replace thermostat if needed.
Insufficient flow.	Ensure hot water is on. Check pressure at both inlets. Pressures must be near-equal, or seats will check and only allow cold water. Need at least 30 psi at both hot and cold inlets. Need at least a 20 degree difference between hot water and set temperatures, as well as cold water and set temperatures. Inspect checks for debris; clean/replace if needed. Remove thermostat and check for debris. Ensure liner can move. Clean thermostat. Replace thermostat if needed.
Temperature fluctuation.	Ensure incoming building pressure is not fluctuating. Inspect supply lines for other equipment that may be reducing pressure to the emergency fixtures. Check pressure at both inlets. Pressures must be near-equal, or seats will check and only allow cold water. Need at least 30 psi at both hot and cold inlets. Need at least a 20 degree difference between hot water and set temperatures, as well as cold water and set temperatures. Inspect checks for debris; clean/replace if needed. Remove thermostat and check for debris. Ensure liner can move. Clean thermostat. Replace thermostat if needed.
Leaks around thermostat.	Remove thermostat and check O-ring. If damaged or worn, replace/tighten.
Water in thermostat.	Check connection. Replace thermometer.



MAINTENANCE

Emergency Combination Shower and Eye/Face Wash System shall be activated on a weekly basis to verify operation and to flush the lines per the American National Standards Institute (ANSI). Inspections shall be recorded with inspector's name and date tested.

Should the need to repair or replace any parts on this station, please contact Stingray Systems. Before any repairs are performed, please verify that the water supply to the station is shut off.

GUARANTEE

We guarantee the Stingray Systems product to be free from defects in workmanship and material, and for a period of eighteen (18) months from date of shipment from the factory or one (1) year from date of installation, whichever occurs first, will replace any parts found by us to be defective. We will not be held responsible, however, for any labor incidental to, or for any damages caused by defective material.

With any questions, please do not hesitate in contacting us at: **1-888-445-4142** or via email at **info@tepid.com**.



WEEKLY TEST RECORD

Month	Test 1	Test 2	Test 3	Test 4
January				
February				
March				
April				
May				
June				
July				
August				
September				
October				
November				
December				
January				
February				
March				
April				
May				
June				
July				
August				
September				
October				
November				
December				

Plumbed emergency eyewashes, eye/face washes, drench hoses, shower, and combinations systems shall be activated and tested for a period long enough to verify operation and ensure that flushing fluid is available.

WARNING: This product contains chemicals known to the State of California to cause cancer and birth defects or other reproductive harm. (Installer: California law requires that this warning be given to the consumer.)
 For more information: www.oehha.org/prop65